



**NOTES**

1. The layout shown above is typical only. Transformer location and sizing and the number of associated L.T. Turrets will be determined in each instance.
2. Supply cables should be separated from supply pipes and cables belonging to other utilities. A minimum of 300mm separation is required from water, gas, or sewerage pipes and telephone cables.
3. H.T. & L.T cable to be buried to depth of 750mm.

**RESIDENTIAL UNDERGROUND  
L.T.SERVICE  
TYPICAL LAYOUT**

**FIG 12**