



NOTES

1. Meters shall be placed in a location readily assessable to the company's meter readers.
2. Each service shall be separately identified and permanently marked to identify the premises being served. (e.g. Apartment No.)
3. All trunking which houses unmetered wiring shall be made with provision for sealing.
4. Customer load wires shall never be installed in trunking that contains unmetered wires.
5. Multimetering installations which are located outdoors shall have equipment designed for outdoors where it will be exposed to the weather.

**TYPICAL MULTIMETERING
INSTALLATION**

FIG 22