



MAXIMUM SERVICE MAST HEIGHT ABOVE LAST FIRM SUPPORT	
DIA.(mm)	RIGID GALVANIZED CONDUIT
50	750
63	1500
75	2400
88	3250

Service drop
5.0m minimum
over roadway

Customer must provide adequate grounding of facilities.

1. A Service Mast (extended weatherhead) may be used to get proper clearance above roadways.
2. Service mast conduit and bracket must be of sufficient strength to support service drop.
50mm diameter or larger rigid galvanized conduit is preferred.
BL&P Co. will not attach service to aluminium or PVC mast.
3. Meter socket to be placed in a location accessible to meter readers.
4. Connections between service entrance conduit to be waterproof.
5. Loadends must be of minimum length of 450mm to allow for drip loop.

**ATTACHMENT OF SERVICE
CABLES AT BUILDINGS
EXTENDED WEATHERHEAD**