



NOTES

1. Barriers are required to protect padmount transformers from physical damage when transformers are installed in car parks and other paved areas used by vehicles.
2. Removable barriers are to be provided when use of fixed barriers would obstruct opening of transformer doors.